



Ref: G/OIB/NPWR-05/2021

STANDARD FORM

for

EXECUTIVE SUMMARY OF BID EVALUATION REPORT

[Issued in terms of section 7(1)(i) of the Public Procurement Act, 2015]

**Namibia Power Corporation (PTY) Ltd
NamPower Centre
15 Luther Street
PO Box 2864
Windhoek, Namibia**

[Tel: +264 61 205 4111

[Fax: +264 61 232 805

Email address: bidclarifications@nampower.com.na

[Website: www.nampower.com.na

Executive Summary of Bid Evaluation Report

Project Title

Reference number of procurement: G/OIB/NPWR-05/2021

1. **Scope of Contract:** Design, Manufacturing, Testing and Delivery of a 61 MVA, 220/6.65 kV YNd5 Power Transformer
2. **Procurement method used:** Open International Bidding
3. **Date of Invitation of Bids:** 22 January 2021
4. **Closing date for submission of bids:** 12 March 2021
5. **Date and place of opening of bids:** 12 March 2021, NamPower Convention Centre
6. **Number of bids received by closing date:** 7
7. **Responsiveness of bids:**

Bidder' s Name	Pricing at Bid Opening N\$	Responsive or not responsive (Yes/ No)	Reasons why bid is not responsive
SGB-Smit Power Matla	14,483,600.00	No	<ul style="list-style-type: none">• Failed to furnish their complete list of testing equipment and facilities for the following tests: Acoustic noise level measurement• Leak testing with pressure• Infrared scanning.
Actom Energy Namibia	18,190,145.00	No	<ul style="list-style-type: none">• Failed the technical evaluation because they did not submit a Quality Assurance plan document and also did not submit test report for the appropriate rating as was indicated in the bidding documents.
ZEST WEG Group	20,110,396.78	No	<ul style="list-style-type: none">• Presented deviations to the specifications, namely:<ul style="list-style-type: none">- Transformer short circuit current (primary and secondary windings) and impulse test voltage offered were well below specified values- Factory tests for temperature rise and acoustic noise level were not included in offer but available at additional cost.

Hyosung Heavy Industries Corporation	25,327,880.00	Yes	
Protecton Engineering Namibia	23,022,512.62	No	<ul style="list-style-type: none"> • Did not meet the requirement for the minimum average annual turnover between the financial years 2017&2019 • Offering goods as a trader and not as an original equipment manufacturer (OEM), did not meet the criteria for the value of orders handled previously (insufficient value) and didn't supply support from the manufacturers of the goods.
Tesla Energy Solutions	17,135,100.00	No	<ul style="list-style-type: none"> • Bidder's list of similar reference projects not attached • Latest 3 year audited and signed financial statements not attached.
Hitachi - ABB	24,712,699.00	No	<ul style="list-style-type: none"> • Bid Securing declaration not completed and signed.

8. Price comparison for bids that are substantially responsive: 1

Name	A. Price at Bid Opening N\$	B. Bid Price after corrections including contingencies	C. price after Adjustments N\$	D. Price after Margin of Preference [If applicable]	Rank
Hyosung Heavy Industries Corporation	25,327,880.00				1

9. Best Evaluated Bid: **Hyosung Heavy Industries Corporation**